

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 1 PAGES
2. AMENDMENT/MODIFICATION NO. R0001		3. EFFECTIVE DATE 10/28/05	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)
6. ISSUED BY US ARMY ENGINEER DISTRICT, AK CEPOA-CT (W911KB) PO BOX 6898 ELMENDORF AFB, AK 99506-0898 RON JACKSON 907-753-5596		CODE J4P0000	7. ADMINISTERED BY (If other than Item 6) CODE US ARMY ENGINEER DISTRICT, AK CEPOA-CO-NAO PO BOX 35066 (Bldg 3025) FT WAINWRIGHT, AK 99703-0066		DACA85
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) CODE 089C4 FACILITY CODE			IXI 9A. AMENDMENT OF SOLICITATION NO.		
			X W911KB-06-T-0002		
			9B. DATED (SEE ITEM 11) 10/25/05		
			10A. MODIFICATION OF CONTRACT/ORDER NO.		
			10B. DATED (SEE ITEM 13)		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

- ☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.
- Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
- (a) By completing Items 8 and 15, and returning 0 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

PROJECT TITLE AND LOCATION: Public Address System and Sound Reinforcement System, Bassett Hospital, Ft Wainwright, Alaska

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

- (X) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Request for Quote due date is 23 Nov 05, 2:00pm (Alaska time), US Army Engineer District-AK, 2204 Third Street, Elmendorf AFB, AK

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF SIGNER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

2.5 AMPLIFIER POWER RATINGS

Provide a mixer amplifier or mixer power amplifier combination for each zone listed below with a power rating equal to or greater than 140%, of the specified load. Load values shall be based on all line matching transformers being tapped at 1 watt unless otherwise noted. Power ratings listed under "AMP" are for minimum common, commercially available sizes.

Amplifier Power Requirements

Department	Zone	Load	AMP
Circulation Zone (Circ):	Levels 0 & 1	107w	150w
(Note 1)	Levels 2, 3 & 4	91w	150w
PAD	1-02	18w	30w
Pathology	1-03	26w	60w
Radiology	1-04	21w	30w
Emergency Service/Amb Garage	1-07/08	22w	30w
Primary Care Clinic A	1-09	32w	60w
Primary Care Clinic B	1-15	34w	60w
Food Service (Note 1)	1-16	36w	60w
Logistics	1-17	26w	60w
Pharmacy	1-18	9w	30w
Ortho/Surg	1-20	13w	30w
EENT	1-21	12w	30w
Primary Care/Path/Rad Wait	1-24	21w	30w
VA	1-25	10w	30w
CEP	1-30A/B	11w	30w
Labor & Delivery	2-02	16w	30w
Central Sterile	2-03	6w	10w
Surgery	2-04	35w	60w
Inpatient Services	2-06	25w	60w
Dental Care	2-14	14w	30w
Information Man. (Note 1)	3-01	10w	30w
Command Suite/Nursing Admin/ Training & Security	3-02/03	10w	30w
All Call - (Departmental Zones)(Note 2)		7w	30w
Power for following zones:			
CSD	1-06		
Tri Care	1-22		
Alarm Monitor Room	1-26		
Emergency Page/Music Only Channels (Microphone Paging) (Note 3)		100w	150w (Two)
Power for following zones:			
All Music Only Rooms			
Physical Therapy	1-19		
Company Command	2-08		
Personnel	2-10		
Logistics HQ	2-11		
Resource Center	2-12		
Resource Management	3-04		
Quality Assurance	3-05		

Conf. Center (EP only) 3-08

Note 1: Reference TC4 series Telecommunication Plans Keyed Note 12 for speakers tapped at Two(2) watts, in environments with high ambient noise.

Note 2: Amplifier intentionally oversized for future expansion of All Call Zone.

Note 3: Two Mixer/Amplifiers required, one for each program music source, both function as emergency Paging Amplifiers.